



## NSF Product and Service Listings

These NSF Official Listings are current as of **Thursday, January 03, 2013** at 12:15 a.m. Eastern Time. Please [contact NSF International](#) to confirm the status of any Listing, report errors, or make suggestions.

Alert: NSF is concerned about fraudulent downloading and manipulation of website text. Always confirm this information by clicking on the below link for the most accurate information:

<http://www.nsf.org/Certified/PwsComponents/Listings.asp?Company=C0028348&Standard=061&>

# NSF/ANSI STANDARD 61 Drinking Water System Components - Health Effects

**NOTE: Unless otherwise indicated for Materials, Certification is only for the Water Contact Material shown in the Listing. Click here for a list of [Abbreviations used in these Listings.](#)**

## Square D Company

8001 Knightdale Boulevard  
Knightdale, NC 27545  
United States  
888-778-2733  
919-266-3671

[Visit this company's website](#)

**Facility :** Apodaca/Nuevo Leon, Mexico

### Mechanical Devices

Trade Designation	Size	Water Contact Temp	Water Contact Material
Switches/Sensors 9013F(A)(B)(CC)(DDD)(E)[G]	[1]	CLD 23	MLTPL

[1] The following configurations are Certified:

- (A) - Mechanism type
  - R - Reverse action
  - S - Standard adjustable differential
  - T - Non-adjustable differential
  - Y - Higher HP with adjustable differential
- (B) - Enclosure type
  - G - NEMA1 General Purpose Electrical Enclosure
  - W - NEMA3R Outdoor Electrical Enclosure
- (CC) - Fluid connection type
  - 1 - 1/8" NPSF internal threads
  - 2, 12, 22, 32, 42, 52, 62, 72, 82, 92 - 1/4" NPSF internal

3, 13, 23, 33, 43, 53, 63, 73, 83, 93 - 3/8" NPSF internal  
4 - Narrow Differential  
8, 18, 28, 38, 48, 58, 68, 78, 88, 98 - 1/4" Flare  
9, 19, 29, 39, 49, 59, 89, 99 - 1/4" NPT external  
10 - 1/4" Bayonet, barbed  
20 - 90° Elbow, 1/4" bayonet

(DDD) - Pressure Regulation

J15 - J99

(E) - Pulsation plug

"P" or blank

[G] Product also Certified to NSF/ANSI 61, Annex G and is in compliance with California's Health & Safety Code Section 116875 (commonly known as AB1953) and Vermont Act 193. Weighted average lead content <=0.25%; Solder and flux lead content <=0.2%.

NOTE: NSF has not conducted production control audits at this facility. Product Listing is based on type testing [ISO/TEC Guide 2: 1996(E/F/R) 14.5]

---

Number of matching Manufacturers is 1

Number of matching Products is 1

Processing time was 0 seconds

- [Search Listings](#) |
- [News Room](#) |
- [About NSF](#) |
- [Careers](#) |
- [NSF Mark](#) |
- [Client Log-In](#)
  
- [Privacy Policy](#) |
- [Site Map](#) |
- [Request Info](#) |
- [Contact Us](#) |
- [Copyright © 2004 NSF International.](#)